

## EU Declaration of conformity no 0189/3/EU/BITNER

1. Product: **YKXSFOyn(żo), YKXSFTznyn(żo); 0,6/1 kV**
2. Manufacturer: **Cable Factory BITNER Sp. z o.o., 3/3 Józefa Friedleina St, 30-009 Kraków**  
**Production plant: 2 Krakowska St, 32-353 Trzyciąż**

3. This Declaration of Conformity is issued under the sole responsibility of the manufacturer.

4. Scope of Declaration: **Flame retardant, armoured power cables**

Designated as:

**BITNER YKXSFOyn(żo), YKXSFTznyn(żo) ; 0,6/1 kV**

5. Scope of this Declaration stays in accordance with **LVD 2014/35/EU** Directive and corresponding provisions of EU harmonization legislation.

6. References of standards and/or technical specifications or their parts applied to the product being subject of this declaration of conformity:

- harmonized standards:

No	Title
EN 60228	Conductors of insulated cables
EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable. Procedure for 1 kW pre-mixed flame
EN 60332-3-24	Tests on electric and optical fibre cables under fire conditions - Part 3-24: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category C
-	-
-	-
-	-

- other standards and/or technical specifications:

No	Title
ZN-CB-21:2005	Power cables screened or unscreened, armoured or unarmoured for rated voltage 0,6/1 kV type Y(A)KY, Y(A)KXS, X(A)KXS
based on: IEC 60502-1	Power cables with extruded insulation and their accessories for rated voltages from 1 kV (Um = 1,2 kV) up to 30 kV (Um = 36 kV) - Part 1: Cables for rated voltages of 1 kV (Um = 1,2 kV) and 3 kV (Um = 3,6 kV)
-	-

7. Additional information: -

Trzyciąż, 2026-01-23

Place and date of issue

**ZAKŁADY KABLOWE BITNER**

sp. z o.o.

Ul. Józefa Friedleina 3/3, 30-009 Kraków  
Dyrektor ds. Rozwoju, Certyfikacji, Kontroli Jakości oraz ZSZ

*Ireneusz Sosnowski*

name and signature of authorized person